

City of Hot Springs, Arkansas

Quote Form				
Description				
PROVIDE & INSTALL 5 TON SPLIT HVAC SYSTEM AT CENTRAL FIRE STATION, 310 BROADWAY STREET, HOT SPRINGS, AR				
Specifications (if not attached)				
SEE ATTACHED SPECIFICATIONS				
Pages to be returned with bid (in order for bid not to be rejected)				
Pricing	Description	Quantity	Unit Price	Extended Price
Item 1	5 Ton Split System	1		
Item 2				
Item 3				
Item 4				
Item 5				
Total (use this line if there is a separate cost sheet)				
Freight/Delivery (must be shown separately)				
Bid Total				
Number of 12-month extensions (see bid for conditions):				
Taxes - Taxable goods and services delivered inside the City of Hot Springs will have a tax rate of 9.5%. This should not be included in the totals above. All other goods and services will be taxed at the rate required by the applicable governing bodies.				
Guaranteed Date of Delivery (if applicable):				
Execution of Bid (to be completed by bidder)				
Upon signing this bid, I/we have read and agree to the requirements set forth in this bid request and proposal including specifications, instructions to bidders, terms and conditions of bidding, terms and conditions of purchase and pertinent information regarding this bid, and agree to furnish the requested items at the prices stated above. UNSIGNED BIDS WILL BE REJECTED				
Name of Bidder		Phone Number		
Street/PO Address				
City, State, ZIP		Fax Number		
Email Address				
Signature		AR Tax Permit #		
Printed Name				
Title		State Contractor License #		
Do you have a City of Hot Springs business license?		YES ____	NO ____	

QUOTE SPECIFICAITIONS
FOR
HVAC SYSTEM FOR CENTRAL FIRE STATION

The City is accepting quotes for providing and installation of new HVAC system at the Central Fire Station, 310 Broadway Avenue, Hot Springs, AR. The following specifications described are the minimum requirements for the HVAC system. City reserves the right to review manufacturer's specifications and to choose the unit deemed to be in the city's best interest. Bidders are hereby advised that serviceability and functionality will be factors of award in addition to price.

Provide & install a 5 ton split system with gas furnace.

Furnace should be minimum of 90% efficiency.

A/C system should be minimum of 15 Seer.

Line sets can be run down exterior of building but should be covered.

All roof penetrations (if needed) must be done by certified roofer. This cost must be included in the successful bidder's price.

Adding 6 to 8 supply ducts.

Also will be relocating 6 to 8 supply ducts and return ducts.

All permits, duct work, equipment, plumbing, electric, venting, and gas piping should be included in quote.

Maintain clean and safe work area during the installation and removal of materials.

THERE WILL BE A MANDATORY PREBID MEETING 9:00 AM, MONDAY, APRIL 06, 2020
AT THE CENTRAL FIRE STATION, 310 BROADWAY AVENUE, HOT SPRINGS, AR.

RETURN QUOTES TO MARY BURKS at mburks@cityhs.net or fax to 501-321-6833 BY 5:00 pm, MONDAY,
APRIL 13, 2020

STATEMENT OF COMPLIANCE

Bidder shall read all attachments and instructions carefully. Failure to completely become familiar with all attachments and notes will not be deemed just cause for claims or errors.

Any EXCEPTIONS to specifications, individual data sheets, drawings, terms and conditions or any other documents forming part of this Invitation to Bid must be clearly defined and set forth in Bidder's response on this form. To be considered for an award, the Bidder must certify to either A or B below and explain exceptions, if any, on this form (and attachments, if needed).

A. "This bid is in exact accordance with the specifications, drawings, terms and conditions and other requirements of this Invitation to Bid with NO EXCEPTIONS."

*** OR ***

B. "This bid is in exact accordance with the specifications, drawings terms and conditions and other requirements of this Invitation to Bid with the EXCEPTIONS listed below:" (List the number of or restate the specification excepted and in detail explain the exception. Add additional pages if necessary.)

Specification Number	DESCRIPTION (MARK EITHER "A" OR "B" ABOVE. IF "B" SHOW HERE AND/OR ATTACH A SHEET DETAILING EXCEPTIONS)

Bidder's Signature

Bidder's Trade Name (Company, Individual, etc.)

Date Signed

INSURANCE REQUIREMENT COMPLIANCE

PROJECT – PROVIDE LABOR AND MATERIALS TO INSTALL HVAC SYSTEMS AT THE CENTRAL FIRE STATION, 310 BROADWAY AVE, HOT SPRINGS, AR.

When checked in the left column below, certificates of insurance for the type coverage named must be returned with the bid.

Bidder is to indicate by checking the right column, the certificates that are returned with the bid.

<input checked="" type="checkbox"/> General Liability Minimum Amount <u>\$500,000</u>	<input type="checkbox"/> General Liability
<input type="checkbox"/> Vehicle Liability (must be at least in legally required amount)	<input type="checkbox"/> Vehicle Liability
<input checked="" type="checkbox"/> Workers Compensation	<input type="checkbox"/> Worker Compensation
<input type="checkbox"/> Builders Risk Minimum Amount	<input type="checkbox"/> Builders Risk
<input type="checkbox"/> Personal Injury Minimum Amount	<input type="checkbox"/> Personal Injury

Bidder Printed Name

Bidder Signature