



SIDEWALKS SHALL BE CONSTRUCTED ON A PREPARED SUBGRADE TO NOT LESS THAN 90% OF MODIFIED PROCTOR DENSITY (AASHTO T-180). THE MINIMUM WIDTH SHALL BE FOUR FEET (4') AND FIVE FEET (5') FOR A COMMERCIAL DEVELOPEMENT AND THE MINIMUM THICKNESS SHALL BE FOUR INCHES (4"). THE SIDEWALK SLAB SHALL SLOPE TOWARD THE CURB AT THE RATE OF FROM ONE-QUARTER TO ONE-HALF INCH PER FOOT (1":12" TO 1/2":12:)

EXPANSION JOINTS NOT LESS THAN 1/2" THICK OF PREMOLDED, NONEXTRUDING TYPE SHALL BE EVERY 40'-0" OR LESS TRANSVERSE TO SIDEWALKS AND AT ALL POINTS WHERE WALKS MEET CURBS, DRIVEWAY APRONS, WHEELCHAIR RAMPS OR BUILDINGS. ALL SLABS SHALL BE GROOVED NOT LESS THAN TWENTY PERCENT (20%) OF FULL DEPTH AT INTERVALS NOT EXCEEDING SIDEWALK WIDTH

CITY OF HOT SPRINGS		SCALE: NONE
ENGINEERING DIVISION		DESIGNED BY:
SIDEWALK DETAIL		DRAWN BY: JML
		CHECKED BY:
		DATE: 02/25/22
		SHEET NO.